

**Greenville Utilities Commission
Greenville, North Carolina
Questions and Answers for RFB 22-17, Due 03.24.2022 at 3:00 pm**

Question:

The matl for the arm is A871 on the dwg, that is weathering, but the BOM says galv and I believe the entire bid package is for galv.

Could you just verify the arm to be galv, A572?

Answer:

All Material for this bid should be Galvanized Steel.