

**GREENVILLE UTILITIES COMMISSION
GREENVILLE, NORTH CAROLINA**

**SPECIFICATIONS AND BID DOCUMENTS
FOR
THIRTY (30) CAPACITOR CONTROLLERS**

April 5, 2011

TO: All Prospective Bidders and Others Concerned

SUBJECT: ADDENDUM NO. 1

The intent of this addendum is to notify all prospective bidders and others concerned that the Specifications and Bid Documents are hereby modified as follows:

1. Replace page 7 with the attached Addendum No. 1.

The foregoing changes shall be incorporated in the Specifications and Bid Documents.

Please acknowledge receipt of this addendum by e-mailing Cleve Haddock, Purchasing Technician at haddocgc@guc.com.

Accessories (provided by vendor)

Neutral current transformer provided with 10' cable

Cabinet..... direct pole mounted, bottom cable access, holes to be field installed

Cable Modem..... Dual band 800/1900 MHz, CDMA/1xRTT on Verizon network, equivalent Air Link Raven XE

Antenna..... top-mounted, dome type, dual band 800/1900 MHz, ground plane shall be provided

Coax cable & connectors... installed from cable modem to dome antenna

(Customer provided)

Cabinet interface holes field installed

Control cable field provided with voltage, control, neutral sensing

Junction Box provided on the capacitor rack for cable

- Notes:**
- (1) All item(s) will be purchased in box quantities.
 - (2) Bidders are to specify on the attached Request for Proposal Form the brand name of all item(s) quoted, if more than one brand is approved and the expected delivery time.

Method of Award:

Item(s) (1) will be awarded as a total quote.

[The balance of page left blank intentionally]