

GUC CNG VEHICLE REFUELING STATION

Greenville Utilities Commission of the City of Greenville, NC

Purpose of Addendum:

- 1) Answer proposer's questions

Reference Section: Base Design/Build Specification, Section 18000 – General, 1.01C.

- 1) Please confirm the alternate price for the larger canopy would include both a dual hose light duty and a single hose heavy duty dispenser, with additional island form and fuel management system?

RESPONSE:

There are two different canopy options:

- a. The first (smaller) option would apply if the Owner selects the one dual hose dispenser and cardlock.
 - b. The second (larger) option would apply if the Owner selects either or both optional dispensers and in this case, the Owner will select the second island option --the cost of the second island is to be provided as a separate option—as the Owner may elect to install two islands but no canopy. Note that on the larger canopy the number of lights must be increased to 15. The larger canopy will not be selected without also selecting the second (optional) island.
- 2) Can you confirm that with the additional (2) dispensers as alternates, that there will be an additional 30,000scf cascade storage system. We are interpreting that the alternate bid will have two additional dispensers and one storage system. (In addition to fuel canopy, island, fuel management, etc.)

RESPONSE:

- a. These items are to be priced as individual options.
- b. The Owner may elect to purchase additional storage with or without additional dispensers.
- c. Similarly, the Owner may purchase either or both additional dispensers without increasing the storage.
- d. The Owner may also elect to purchase the optional second island without purchasing either of the optional dispensers.
- e. As noted above, the cost of the second island is to be broken out as a separate item. This cost of the second (optional) island must include the pits for both future dispensers, as well as all conduit and piping leading from the compressor compound to the optional second island and from the cardlock to each of the optional dispenser pits.

ADDENDUM NO. 8

ISSUED: May 27, 2011

GUC CNG VEHICLE REFUELING STATION

Greenville Utilities Commission of the City of Greenville, NC

**Please acknowledge receipt of this Addendum in the appropriate location in Section E
– Price Proposal.**

Attachments: (0)