

**GREENVILLE UTILITIES COMMISSION
GREENVILLE, NORTH CAROLINA**

**SPECIFICATIONS AND BID DOCUMENTS
FOR
TWO (2) 20 MVA, 115 TO 13.2Y/7.62 kV POWER TRANSFORMERS
WITH LTC FOR SUGG PARKWAY AND FROG LEVEL SUBSTATIONS**

March 21, 2011

TO: All Prospective Bidders and Others Concerned

SUBJECT: ADDENDUM NO. III

The intent of this addendum is to notify all prospective bidders and others concerned that the Specifications and Bid Documents are hereby modified as follows:

1. Replace page 31 with the attached Addendum No. III.

The foregoing changes shall be incorporated in the Specifications and Bid Documents.

Please acknowledge receipt of this addendum by e-mailing Cleve Haddock, Purchasing Technician at haddocgc@guc.com.

GREENVILLE UTILITIES COMMISSION

PROPOSAL FORM

TWO (2) 20 MVA, 115 to 13.2Y/7.62 kV POWER TRANSFORMER WITH LTC

FOR SUGG PARKWAY AND FROG LEVEL SUBSTATIONS

The undersigned bidder hereby declares that it has carefully examined the enclosed detailed specifications for the furnishing of Greenville Utilities with the items listed below. The undersigned bidder further agrees, if this proposal is accepted within sixty (60) days from the date of the opening, to furnish any or all of the items upon which prices are quoted at the price set opposite each item. Delivery shall be FOB Greenville, North Carolina, within the time indicated below:

<u>Description</u>	<u>Estimated Quantity</u>	<u>Total Price</u>
(I)		
Substation transformer, dual rated 20.00/26.67/33.33/ MVA ONAN/ONFA 55°C and 22.40/29.87/37.33 MVA ONAN/ONFA 65°C, 115 kV delta primary voltage, 13.2Y/7.62 kV secondary voltage, designated for delivery to Operation Center and Frog Level Substation, (Five (5)-year warranty) all in accordance with specifications	2	\$ _____

Delivery _____ (Days)

DEDUCT NO. 1-1

Subtotal	\$ _____
Deduct for Temperature Rise Test	\$ _____
Adder for Sound Test	\$ _____
Total Bid Price (Excluding Tax)	\$ _____

* Price includes delivery F.O.B. pad, unloading, at the Operations Center and Frog Level substation sites.