

GREENVILLE UTILITIES COMMISSION

GREENVILLE, NORTH CAROLINA

ADDENDUM I FOR RFB #19-18

To: All Prospective Proposers and Others Concerned

Subject: Addendum No.1

The intent of this addendum is to notify all prospective proposers and others concerned that the Specifications and Documents are hereby modified as follows:

1. Replace page 4 with the below.

The foregoing changes shall be incorporated in the Specifications and Documents.

Please acknowledge receipt of this addendum by e-mailing Cleve Haddock, Purchasing Department, Buyer II at: haddocgc@guc.com (252) 551-1533

SECTION II

GREENVILLE UTILITIES COMMISSION

SPECIFICATIONS FOR BALL VALVES AND STRAINERS

APRIL 10, 2019

- Item I **Valve, 2" Plastic**, Polyethylene ball valve body must be PE2406, min. pressure rating 80 PSIG, valve stub ends prepared to butt fusion with SDR11 PE pipe, must meet or exceed requirements of USDOT 49CFR-part 192 for natural gas distribution. Kerotest Part No.99042011 Full Port Valve, Nordstrom #C84211, Perfection #46000, or RW Lyall #LPVR200Y-AT. (GUC Stock #504840)
- Item II **Valve, 4" P.E.**, Polyethylene ball valve body must be PE2406, min. pressure rating 80 PSIG, valve stub ends prepared to butt fusion with SDR11 PE pipe, must meet or exceed requirements of USDOT 49CFR-part 192 for natural gas distribution. Kerotest Part #99044011 Full Port, Nordstrom Valve #C84111 Full Port, or Perfection #47000. (GUC Stock #505210)
- Item III **Valve, 6" Poly Ball P.E.**, Polyethylene ball valve body must be PE2406, min. pressure rating 80 PSIG, valve stub ends prepared to butt fusion with SDR11.5 PE pipe, must meet or exceed requirements of USDOT 49CFR-part 192 for natural gas distribution. Kerotest #77313260, 99046011 Full Port, Nordstrom #C84111 Full Port, or Perfection #48001. (GUC Stock #505240)
- Item IV **Valve, 2" Ball, Steel, Weld Ends**, 2" Steel Ball Valve, Weld/Weld Class 150, coated for UG service, marked in accordance W/DOT Part 192.63, complete w/2" square operating nut, ¼ turn, Full Port. Model No. is 2WBFP285-W – Part No.72631377: 2" Class 150 Full Port Weldball Valve - Weld Ends
(GUC Stock #505800)
- Item V **Tee, 2" Strainer w/ Flanged Ends**, W/150# Raised Face Flanges, Stainless Steel Basket w/40 mesh liner. Kerotest #54009584 Cat #TST-215-FF-40, or Royal Guard Type 59. (GUC Stock #505880)
- Item VI **Valve, ¾" Ball, Steel, Weld Ends**, ¾" Steel Ball Valve, Weld/Weld CL150, coated for UG service, marked in accordance W/DOT Part 192.63, complete w/2" square operating nut, ¼ turn. Kerotest Model #0.75/WB-275W.
(GUC Stock #505810)
- Item VII **Valve, 4" Ball, Steel, Weld Ends**, Steel, Weld ends, CL150, coated for underground service, marked in accordance with DOT Part 192.63, complete with 2" square operating nut, ¼ turn, Full Port, Model No. is 4WBFP285-W – Part No. 72660092: 4" Class 150 Full Port Weldball Valve - Weld Ends
(GUC Stock #505820)