

QUESTIONS AND ANSWERS II FOR:

RFB # 20-22, 04/30/2020 FOR

DIRECTIONAL BORING SERVICES

1. Is there a general length of most of the bores? This is important to know as set up and relocation of equipment greatly impacts the cost. **Generally, between 200 and 500'.**
2. Please clarify what is required for item #11 and #12. **The boring contractor will not be allowed to make conduit tie-ins to energized facilities. Bore shots longer than the drills capability require the pipe to coupled or tied-in to make a continuous conduit path. GUC does allow the contractor to couple the conduit in those instances. We are requesting a price for the conduit tie-in in the job task table.**