

QUESTION AND ANSWERS

FOR #20-25 TUBULAR STEEL STRUCTURES

DUE JUNE 25, 2020 @ 4:00 PM (EDST)

1. We will need the Ica files and or the load tree drawings for the Engineered structures on this project, in order to create a design.

These files will be on our GUC website at www.guc.com

2. Structure 3 is Pre-Engineered pole as per the structure list but .Ica file is provided for this. Please confirm if this structure needs to be designed. From the given .Ica files we cannot judge the load points considered in this on to the structure. We need PLS bak file /models or the attachment points marked on the drawing to continue work on this.

Answer:

Structure 3 is a Pre-Engineered pole. However, structure 3.Ica file was provided to give manufacturers the load information needed to design Davit Arms. See "Note 3" on drawing TS.DC.DA1 for structure 3.

These files will be on our GUC website at www.guc.com