

Response to Request for Clarification 3

Contractor: PCA Engineering, Inc.

Questions/Comments:

PCA Engineering, Inc.

- **Is piping at the three (3) sites above grade or below grade and are there test stations available at each site?**

Gas piping at each site is below grade and no test stations are available at those locations. There are test stations in other parts of the system.