

**QUESTIONS AND ANSWERS (2) FOR:**

**RFB # 13-32, 09-24-13**

**RFB for two (2) 55,000 gallon shop fabricated horizontal LNG storage tanks**

**Question:** Please clarify if the scope of this bid includes installation of the tanks or just fabrication and delivery to the site, with installation being arranged by the purchaser?

**Answer:** Scope of Supply includes fabrication and delivery to the site of all equipment and materials described in 'Specification for Shop Fabricated LNG Storage Tank' and on drawing number GRN-0056-D5. Installation will be the responsibility of purchaser.

**Question:** Is there a specific requirement for a manway?

**Answer:** There is not a requirement for a manway access for the tanks.

**Question:** Beyond the components identified in Section 2.5.3 (Tank Subsystems), please clarify the extent of the vendor's responsibility in regards to the scope of piping/tubing/valves/fittings/etc external to the tank, i.e. please identify the point(s) at which the vendor transfers responsibility to the owner/purchaser.

**Answer:** Please see 'Specification for Shop Fabricated LNG Storage Tank', Page 2, section 2.2 – Scope of Supply.

**2.2 SCOPE OF SUPPLY**

The Vendor's scope of supply shall consist of all equipment and materials described in this specification and shown on attached drawing number GRN-0056-D5.

All piping, tubing, instrumentation, fittings, valves, etc. shown on drawing number GRN-0056-D5 are included in vendor's scope of supply. The responsibility transfer points from vendor to purchaser are essentially where any blind flange, screwed cap, or weld cap (all to be supplied by vendor) is shown.