

**RFB FOR LIGHT FIXTURES**  
**#14-33**  
**QUESTION AND ANSWERS**

**Question:** Can you please clarify on Item V on the referenced quote? Is this a wallpack, a flood style fixture, or an area light (IE dusk to dawn pole light).

**Answer:** Dusk to dawn area light

**V. 5,000 LED (Security) Light Fixture** - 4,000 – 6,000 delivered lumens, Color Correlated Temperature ( CCT) 4,000 – 5,000 K, 120-277 volts, Power Factor > .90 at 120 VAC, Total Harmonic Distortion (THD)< 20%, Type V distribution pattern, accept 2" O.D. arm, minimum 10KV class C arrestor, LM-79 & LM-80 test data, ANSI C136.41 seven (7) position NEMA receptacle, Fixed Drive Current, ANSI C136.15 label "50 LED", minimum five (5) year warranty, approved vendors shall be American Electric Lighting, Leotek, Cooper, Holophane, Cree, Energy Lite.

***Vendor to maintain minimum of 50 units in stock (GUC Stock # 212360)***

Thanks.

8/15/14