

**GREENVILLE UTILITIES COMMISSION**

**GREENVILLE, NORTH CAROLINA**

**ADDENDUM**

RFB for furnishing of approximately (20) 25 KVA Padmount Transformers 240/120, (1) 100 KVA Conventional Distribution Transformers 120/240, (3) 75 KVA Three-Phase Padmount Transformers 120/208.

To: All Prospective Proposers and Others Concerned

Subject: Addendum No.1

The intent of this addendum is to notify all prospective proposers and others concerned that the Specifications and Documents are hereby modified as follows:

1. Replace page(s) 10, with the below.

The foregoing changes shall be incorporated in the Specifications and Documents.

Please acknowledge receipt of this addendum by e-mailing Cleve Haddock, Purchasing Department, Buyer II at: [haddocgc@guc.com](mailto:haddocgc@guc.com) (252) 551-1533

**MISCELLANEOUS:** Aside from compliance with transformer loss requirements, transformers that are found to be damaged upon delivery or fails to otherwise meet all other bid specifications and requirements will not be accepted by the Commission.

**ACCEPTABLE TRANSFORMER MANUFACTURERS:** The following transformer manufacturers are considered acceptable for this bid:

Power Partners/ABB

Central Moloney

Cooper Power Systems

ERMCO

GE/Prolec

Howard Industries

Kuhlman Electric Company

CG Power Systems

Bidders desiring to quote non-accepted transformer manufacturers must first contact the Director of Electric Systems for conditional approval by the Commission for **each** bid.

**Conditional approval shall not constitute acceptance of the manufacturer by the Commission nor a commitment to award all or any part of any current or future bids to the bidder until accepted as an approved manufacturer and added to GUC's specifications as an acceptable manufacturer.** As deemed appropriate by the Commission, additional conditions or requirements may be extended as a condition of any purchases or awards.

**SUBMIT BIDS ON ATTACHED PROPOSAL FORM**

[Balance of page left blank intentionally]