

QUESTION AND ANSWERS FOR:

RFB # 16-14, 4/28/16

STRUCTURES AND EQUIPMENT FOR

GREENVILLE SOUTH 230 KV POD No. 3

1. In the text for the proposal, it calls for 2 direct embedment poles 85/CL2, however, the bill of material calls out 75/CL2. Please verify. **(85 in proposal is correct. BOM is incorrect.)**