

QUESTION AND ANSWERS FOR:

RFB # 16-17, 5/11/16

PREFABRICATED METAL RELAY CONTROL HOUSE FOR GREENVILLE

SOUTH 230 KV POD No. 3

- 1) The specifications require UL752 Level 4 (30/06) rated exterior doors. However, the specifications describe 24 gauge metal exteriors for the entire remaining structure. Does GUC intend for the entire structure to be bullet resistant or merely the doors? **Remove the requirement for the doors to be UL752 Level 4 (30/06) rated. Also, doors shall be standard 6'-8" high.**

- 2) 21.1.10 requires tempered safety glass with wire reinforcement to be located within the doors. The exterior doors have been specified to be UL752 Level 4 ballistic rated. Do you intend for the door windows to be ballistic rated? **No.**

- 3) Is a fiberglass control buildings an acceptable alternate?
You may use the Exception Form to submit any alternates.

- 4) Will GUC accept bids for pre-fabricated concrete structures or is the solicitation restricted to light gauge metal?
You may use the Exception Form to submit any alternates.