

QUESTION AND ANSWERS FOR:

RFB # 16-31, 7/26/16

Transformers

1. Please have the primary voltage verified on the single Phase pad transformer.

Answer: 7200 V phase to ground