

QUESTION AND ANSWERS FOR:

RFP # 16-33, RFP for 15.5 KV Power Circuit Breakers

1. FVR type design, see attached and advise if acceptable?

Answer: We would not have an issue accepting this breaker.