



- REMOVE EXISTING WRAP, INSPECT, CLEAN, AND RE-COAT GAS PIPE CASING
- INSPECT & REPLACE BRIDGE HANGERS AS NEEDED
- INSPECT CASING FOR CORROSION AT BRIDGE ABUTMENTS
- FILL ANY VOIDS IN THE CASING'S ANNULAR SPACE AT BRIDGE ABUTMENTS
- ALL TRAFFIC CONTROL SHALL BE IN ACCORDANCE WITH NCDOT STANDARDS



Gas Engineering  
801 Mumford Rd  
Greenville, NC 27835 | 252-551-1587

GAS MAIN BRIDGE ATTACHMENT MAINTENANCE

**NC 11**

GREENVILLE      PITT COUNTY      NORTH CAROLINA

Scale: 1" = 300'      Date: 10/04/16      Sheet: 1 of 1



- INSPECT CASING TO ENSURE ADHERANCE WITH DOT REGULATIONS
- INSPECT CASING FOR CORROSION AT BRIDGE ABUTMENTS
- ALL TRAFFIC CONTROL SHALL BE IN ACCORDANCE WITH NCDOT STANDARDS

**Greenville Utilities**  
 Gas Engineering  
 801 Mumford Rd  
 Greenville, NC 27835 | 252-551-1587

GAS MAIN BRIDGE ATTACHMENT MAINTENANCE		
<b>US 264</b>		
GREENVILLE	PITT COUNTY	NORTH CAROLINA
Scale: 1" = 300'	Date: 10/04/16	Sheet: 1 of 1



FIFTH ST

40 LF

GREEN SPRINGS DR

- INSPECT CASING TO ENSURE ADHERANCE WITH DOT REGULATIONS
- INSPECT CASING FOR CORROSION AT BRIDGE ABUTMENTS
- ALL TRAFFIC CONTROL SHALL BE IN ACCORDANCE WITH NCDOT STANDARDS



Gas Engineering  
 801 Mumford Rd  
 Greenville, NC 27835 | 252-551-1587

GAS MAIN BRIDGE ATTACHMENT MAINTENANCE

# FIFTH ST.

GREENVILLE      PITT COUNTY      NORTH CAROLINA

Scale: 1" = 50'

Date: 10/04/16

Sheet: 1 of 1