

**QUESTION AND ANSWERS FOR:**

**# 16-01, DUE 1/20/16**

**RFP FOR SCREENINGS WASH AND PRESS EQUIPMENT SYSTEM**

1. Are you wanting us to include installation or equipment only?

Per the RFP we expect to receive an Equipment (only) price and an Installment (only) price – two different values.

2. On bid package drawings 1 and 2, it is noted for heat tracing for the screenings wash/press discharge piping. This is not noted within specification 11325, is this to be provided by the equipment manufacturer or the contractor?

We would like the Manufacturer to provide the heat tracing as part of the equipment package.