

Greenville Utilities Commission  
18-17 RFB for Gate Station Materials  
Due 5/2/18, Questions and Answers II

1.	ITEM 1 -DO YOU HAVE A PREFERENCE ON THE COLOR OF THE XYLAN COATING ON STUDS AND NUTS? Machine Gray, if possible.
2.	ITEM 7 – DO YOU WANT SCH 40 OR SCH 80 SMLS NIPPLES? SCH 80
3.	ITEM 10-16 – WILL YOU ACCEPT IMPORT WELD FITTINGS AND FLANGES WITH MTRS? Domestic Only
4.	ITEM 18-19 – DO YOU WANT A STD PORT OR FULL PORT BALL VALVES? Full Port