

Greenville Utilities Commission
18-17 RFB for Gate Station Materials
Due 5/2/18, Questions and Answers

Item #17	
Question: What type of material?	
Answer: Stainless	
	Valve, Ball, Threaded Female Ends, Swagelok Series 60 (or
	equal), Class 3000 (stainless)