

GREENVILLE UTILITIES COMMISSION

GREENVILLE, NORTH CAROLINA

ADDENDUM (1) FOR #22-21

RFB FOR INDIRECT NATURAL GAS FIRED WATER BATH HEATER

March 29, 2022 at 4:00 pm

To: All Prospective Proposers and Others Concerned

Subject: Addendum No.1

The intent of this addendum is to notify all prospective proposers and others concerned that the Specifications and Documents are hereby modified as follows:

The foregoing changes shall be incorporated in the Specifications and Documents.

Please acknowledge receipt of this addendum by e-mailing Cleve Haddock, Procurement Manager at: haddocgc@guc.com (252) 551-1533

ADDENDUM NO. 1

March 8, 2022

GREENVILLE UTILITIES COMMISSION

RFB for INDIRECT NATURAL GAS FIRED WATER BATH HEATER

A. SCOPE

This Addendum No. 1 consists of pages AD1-1 through AD1-1.

Proposers are hereby notified of the following changes in the advertisement, specifications, and/or drawings.

B. SPECIFICATIONS

Page 6 of 22 – Replace the **Specifications for Heater** with the following:

Min. Flow:	50 MSCFH
Max. Flow:	600 MSCFH
Inlet MAOP:	1,000 PSIG
Inlet Pressure for Heat Rating Purposes:	800 PSIG
Inlet Temperature:	50 Deg. F

Downstream MAOP:	60 PSIG
Desired Downstream Temperature:	50 Deg. F

This Addendum No. I is submitted as part of the Bid 22-21 RFB for Indirect Natural Gas Fired Water Bath Heater.