

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 22-68

RFB FOR INSTALLATION OF MT. PLEASANT TO SUGG 115KV TRANSMISSION LINE

11/17/2022 at 4:00PM

1. No guys or anchors on this project, correct?

Correct. All poles will be self-supporting.