

**GREENVILLE UTILITIES COMMISSION**

**QUESTIONS AND ANSWERS FOR 22-73**

**RE-BID FOR TWO (2) POWER TRANSFORMERS WITH LOAD TAP CHANGERS**

**1/10/2023 at 2:00PM**

1. Per page 8 of 48, item 6- *"Transport by rail or truck are the only acceptable delivery methods."*  
Please confirm if the Transformer can be transported by Ship and then truck?

Transportation by ship is not allowed at this time.

2. The factory has a question about delivery- in light of the supply chain issues; manufacturers are quoting anywhere from 50-80 weeks. Is there a delivery time required and is this a part of the evaluation?

Delivery time will be a factor in our decision. Our project schedule is based around a 24 month delivery, but it has some degree of flexibility.

3. Were there any changes to the spec?

Nothing has changed in the technical specification.

4. Is there a process for vendor approval of OTC with Greenville Utilities?

Any new vendors would require an approval process before winning the contract.

Approval process has typically included, list of all customers, list of like sized units/customers produced in the last 10 years, factory inspection, and polling existing customers regarding quality of experience with the vendor.