

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 23-06

RFB FOR REPLACEMENT OF DISTRIBUTION POLES ALONG NC-43

1/24/2023 at 2:00PM

1. Will the transformers be transferred or replaced?

The transformers will be transferred from old poles to new.

2. Will transformer units be added, or will they be added to another unit?

No new transformers will be added. Labor costs for transferring the existing transformers shall be included in the labor bid by the contractor.