

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS FOR 23-17**  
**RE-RFP FOR GAS LEAK SURVEY**  
**3/30/2023 at 11:00 AM**

1. What am I not doing correct on the proposal?

Proposers need to ensure they are submitting a proposal that includes a walking leak survey of our system. Mobile leak survey is to be provided only as an alternate to walking. In addition, proposers need to ensure they are including scope of work item 4, which is visual inspection and documentation of every meter set/service point for atmospheric corrosion deficiencies, code violations, accessibility, etc.