

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS III FOR 23-21
RFB FOR TUBULAR STEEL STRUCTURES
5/9/2023 at 3:00PM

1. Per the structure drawings, guy wires will be used on a number of the structures. Can you please confirm whether we need to design the structures based on guy wires being used, and if so can you provide the guy wire properties (diameter, UTS, et.?)?

7/16" EHS Guy Wire

OD: 7/16 in.

UTS: 20,800 lb·f

2. As per the screenshot below from various drawings, Detail 4 shows the crossarm arrangement. Can you please confirm that this is not in the scope of supply of the vendor/manufacturer, and that GUC will provide these crossarms and attachment hardware?

It is not in the scope for this bid. GUC will provide the crossarms and attachment hardware.