

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS IV FOR 23-21
RFB FOR TUBULAR STEEL STRUCTURES
5/9/2023 at 3:00PM

1. Are we only providing holes? If we are to provide the arms, we will need the loading(s) to design the arms.

Yes, the vendor will only be responsible for drilling the thru-holes.

2. What is the height for structure 18.4? 80' or 75'.

75'

3. For structures 18.17-18.18, do they use drawing TPZD1.C2 or TPZD1.C1?

TPZD1.C1 (See revised attachment)