

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS V FOR 23-21
RFB FOR TUBULAR STEEL STRUCTURES
5/9/2023 at 3:00PM

1. For structures 11.1 & 11.2 please provide embedment and pole length?

85' length & 10.5' embedment.

2. What structure 15.1 please provide embedment and pole length?

75' length & 9.5' embedment.

3. For structure 18.14 please provide embedment and pole length?

80' length & 10' embedment.