

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS II FOR 23-37
RFB FOR TRANSFORMERS
9/5/2023 at 3:00PM

1. On the transformer's specifications received for RFB 23-37 is mentioned the impedance value (4.5%) for Pad mount Transformers 750 kVA & larger and not for the one to be quoted.

Can we use the following impedance value for the 3PH Pad mount Transformer 150 kVA, 300 kVA, and 500 kVA that are according to the IEEE std C57.12.34(*):

- 150 kVA: 3.10% - 5.75 %
- 300 kVA: 3.10% - 5.75%
- 500 kVA: 4.35% - 5.75%

1. Please follow Specifications in bid and quote.