

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 24-02

RFB FOR DRESSER DI COUPLINGS

1/25/2024 at 2:00PM

1. I do have some questions on these particular items. After looking at the Romac XR501 version I have determined that there are a couple of different options.

4 thru 8" diameter come in 7 and 12" lengths

10" diameter comes in 8 and 12" lengths

12" diameter comes in 8 and 13" lengths

There is a standard shopcoat painted version and a fusion epoxy coating version for all sizes.

They also have a standard galvanized bolt & nuts option as well as 304 and 316 stainless steel bolt and nut options.

To price this bid correctly we would need to know which of these options is required.

1. 7.2.6.5 Bolted Couplings for PVC C-900 pipe and ductile iron pipe shall be constructed of a center sleeve and end rings of ductile iron in accordance with ASTM A536. Bolts and nuts shall be of high strength, low alloy steel per ASTM A242 and AWWA C-111. Center sleeve and end rings shall have a paint finish coat. Couplings shall be Ford Style FC1, Romac 501 Series, Smith Blair 441, or JCM 201.