

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS II FOR 25-50

RFB FOR 10MW GENERATOR SITE FOUNDATIONS & CONDUITS

8/26/2025 @ 2:30 PM

1. Are we responsible for furnishing and installing the anchor bolts? I know in the past, GUC has completed this scope of work after our concrete is placed and finished?

Anchors to be installed by GUC when generators are set.

2. Will GUC stake and layout the corners of the Generator Pads? This is typical on past similar projects?

GUC shall stake center lines for generator pads.

3. We will not include any soils testing or undercut in our bid package. Please confirm this is not within our scope of work?

Soil testing is not required, but excavation to match pad to grade is in the scope of work.