

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS III FOR 25-55

RFB FOR MACGREGOR DOWNS REGULATOR STATION MATERIALS


9/18/2025 @ 3:00 PM

1. If I could get some clarification for LINE 3 / ITEM III:

4" Valve, Ball, Weld End, ANSI 300, Cameron T-31 or equivalent, Below Grade, Tarsel Coated, 1/4 Turn w/ 2" Nut, w/ Lubrication Lines, Lockable

PLEASE SPECIFY IF STUB UP EXTENSION (#1) OR A PINION SHAFT EXTENSION (#2)

(IF PINION SHAFT EXTENSION, WE NEED TO KNOW THE MEASUREMENT FROM CENTERLINE OF VALVE TO TOP OF 2" SQUARE NUT)



Option 1 above.