

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 25-55

RFB FOR MACGREGOR DOWNS REGULATOR STATION MATERIALS

9/18/2025 @ 3:00 PM

1. On Line 8 below:

6"x8"	Valve, Relief, ANSI 300 x ANSI 150, Flowsafe F7000
-------	--

What is the Set Pressure?

The set pressure on the relief valve for line item 8 will be 70 psi.