

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS II FOR 25-56**  
**RFB FOR MACGREGOR DOWNS GENERATOR STATION MATERIALS**  
**9/23/2025 @ 3:00 PM**

1. Page 5 Item 6. Noticed ASTM spec not noted. Will those be A105 or A694?

ASTM A694.