

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 25-56

RFB FOR MACGREGOR DOWNS GENERATOR STATION MATERIALS

9/23/2025 @ 3:00 PM

1. You need written bids only? Emailed bid forms are not acceptable?

Yes. Yes, you must follow the Bid Instructions.

2. A question to clarify please:

ITEM 38 / page 6

4" Double Pipe Support, EZ-Line, Model DPS-4

The description only states 'Double Pipe Support' but doesn't state which style as EZ Line has the DPS-01 and the DPS-02 (attached)

Are we needing the DPS-01 or DPS-02 style?

Once confirmed, we also need to know if both the top and bottom pipes are 4" and then the heights.

Please use the Spec below:

Double Pipe Support, EZ-Line, Model DPS-02, 4"X4", D1 = 2'-0", D2 = 2'-5" (*) w/ 204-F Upper Cradle/U-Bolt Clamp.

3. PAGE 6 FLANGE ITEMS: FLANGES 22 THROUGH 25

Just confirming to make sure that the flange spec to quote is: A/SA694 F52 CARBON STEEL WELD NECK FLANGE RF. Or if A/SA105 spec is OK here?

The below spec will be needed for the flanges:

A/SA694 F52 CARBON STEEL WELD NECK FLANGE RF.

4. ITEM # 38 - 4" Double Pipe Support, EZ-Line, Model DPS-4

Please confirm which style of DPS is required?

Please use the Spec below:

Double Pipe Support, EZ-Line, Model DPS-02, 4"X4", D1 = 2'-0", D2 = 2'-5" (*) w/ 204-F Upper Cradle/U-Bolt Clamp.

5. Question regarding 1ea - 4" Double Pipe Support, EZ-Line, Model DPS-4. Please specify which style of DPS is required?

Please use the Spec below:

Double Pipe Support, EZ-Line, Model DPS-02, 4"X4", D1 = 2'-0", D2 = 2'-5" (*) w/ 204-F Upper Cradle/U-Bolt Clamp.