

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS III FOR 25-57
RFB FOR GALVANIZED TUBULAR STEEL STRUCTURES
10/9/2025 @ 2:00 PM

Q1. What is the requested delivery timeframe?

A1. Time is of the essence for deliveries. Bidder's should provide delivery time in their bid. Once a bid is awarded the selected bidder will be held to their quoted delivery.

Q2. Could you please clarify what is meant by "minimum embedment"? The embedment values, 10.5, 10, and 11, are considered too small.

A2. Poles 5-10 are direct embed RUS class poles with 10%+2' embedment. For poles 1-4 a minimum diameter and depth is provided. The embedment provided is the minimum length of embedment allowed with the provided base diameter. When the manufacturer optimizes the pole design, if the base diameter is smaller than that provided in the table we will have to re-evaluate the embedment depth.

Q3. Please provide .bak files.

A3. .bak and .lca files have been emailed out and are provided at guc.com.

Q4. There are a few missing dimensions for drawings TS.DC.DA4 and TS.DC.DA6 (structures 2,3, and 6). Would you please request these dimensions?

A4. Davit arm lengths can be found in the description shown in the List of Materials on each drawing. Manufacturer is responsible for designing the davit arm to support the required loads.