

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS II FOR 25-58
RFB FOR HIGH-SPEED TURBO BLOWER
10/2/2025 @ 2:00 PM

1. Please confirm if airflow and discharge pressure for DP1 can be changed to 9,828 scfm and 9.8 psig respectively to match the performance of the existing NX500D blower on site. Please refer to attached blower data plate of the existing NX500D blower on site?

We are fine with the spec of 9,828 scfm at 9.8 psig as it matches our existing equipment exactly.