

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 25-84

RFB FOR PRECAST CONCRETE RELAY CONTROLHOUSE FOR THE BOVIET SUBSTATION

12/18/2025 @ 2:00 PM

1. Is a 14' overall width with a 13' 8" base acceptable?

Yes, so long as all panels shown on the short walls can be accommodated as arranged.