

**GREENVILLE UTILITIES COMMISSION**

**QUESTIONS AND ANSWERS FOR 25-84**

**RFB FOR PRECAST CONCRETE RELAY CONTROLHOUSE FOR THE BOVIET SUBSTATION**

**12/18/2025 @ 2:00 PM**

1. We will be quoting this building as 13'8" wide at the base (14' overall width w/ 2" roof overhangs), in lieu of the 14' base (14'6" w/ roof overhang) in efforts to provide more cost-effective freight. If we can keep it under 14' overall that would be the way to go.

14' overall width would be an acceptable alternate.