

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS FOR 26-07
RE BID FOR RECOATING OF METER/REGULATOR PIPING
2/26/2026 @ 3:00 PM

1. Will the tent need to be erected after the coating is sprayed for overnight curing, or should this tent be put up (encapsulated) for the entire blasting and coating process?

The tent can be erected once the curing process begins. However, if there is a chance of condensation during the blasting and coating process that will damage the final product, the tent needs to be erected during this process as well.

1. What is the start date for this project.

The vendor that is awarded the project can start immediately after the award.