

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS II FOR 26-13**  
**BIDS FOR BOVIET SUBSTATION FOUNDATIONS**  
**4/23/2026 @ 2:00 PM**

1. Will GUC provide an Excel copy of the SOV?

An Excel copy is provided for simplicity of completion, but the bid shall be submitted on the standard proposal form.

2. Can GUC verify if the conduit and grounding system will be in place prior to mobilization? Section 7.0 Conduit Systems on Page 35 of the SOW states "A complete conduit system with associated couplings and fittings shall be provided for equipment interconnection".

Grounding system shall be installed by others after completion of foundations. Conduits are to be installed by foundation contractor as indicated for generator foundations and security foundations.

3. Can the breaker pad foundations (P-10 and P-11) be added to the Pricing Sheet?

Proposal sheet has been updated.

4. Is the SPI Filter being provided by GUC?

Yes, the SPI filter and housing will be provided by GUC. The drain piping is to be provided by the contractor.