

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS FOR 26-14
BIDS FOR PEAK SHAVING GENERATOR SYSTEM GAS PIPING
4/16/2026 @ 2:00 PM

1. Is GUC providing the 4" valves? If not, can you please provide the specs/type/details for the 4" valves?

No. See 8.3 in spec.

2. Will Contractor be furnishing and or installing any pipe supports for the 4" piping?

Yes.

3. Will GUC install the ½" sense lines?

No.