

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS II FOR 26-17**  
**BIDS FOR BOVIET SUBSTATION LABOR & CONSTRUCTION**  
**5/7/2026 @ 2:00 PM**

1. Are stress cones provided by GUC or contractor?

Cables are installed and terminated by GUC.