

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS FOR RE-BID 26-39
FOR BOVIET SUBSTATION LABOR & CONSTRUCTION
6/12/2026 @ 2:00 PM

1. Section 7.5.1. It says the contractor is responsible for all junction boxes. Do you have a count of how many, size of them, and what material would go in them (terminal blocks, fuse blocks, bus bars, ext.)?

Junction boxes are not necessary or required on this project.

2. Is someone else taking care of the spoils, grading, and rocking?

Contractor is only expected to remove spoils and return to grade the areas for the installed cable trench and conduit systems. Rock is installed by others.