GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR RFB 26-68

FOR RELOCATION OF 12.47KV DISTRIBUTION STRUCTURES AND 115KV TRANSMISSION STRUCTURES ALONG EVANS

12/1/2026 @ 2:00 PM

1. Will the distribution be able to be de-energized to be able to install the caisson and new transmission pole at Str 1 and Str 1A?

We will de-energize, if possible, to help with installation but this is not a guarantee that every circuit can or will be de-energized.