

BOVIET Transmission Pre-Bid Q&A

Date: 3/11/2026

1) Q: Can GUC provide a map with the correct structure numbers clearly labeled?

A: Yes, please see Addendum 1 to the Labor Bid for map with structure numbers.

2) Q: Can GUC provide Geotech report for Boviet Transmission Project?

A: Yes, please see Addendum 2 to the Labor Bid for Geotechnical Report.

3) Are there any permits required prior to construction, e.g. wetlands, DOT, etc?

A: No permits will be required. Construction will take place in GUC R/W and easements.

4) Q: Is there a laydown yard where poles will be delivered?

A: Yes, GUC has a pole laydown yard on Holly St across from 801 Mumford Rd. The manufacturer will deliver pole sections to this location.

5) Q: Does GUC have a dump site for spoils?

A: Due to the small scope of this project, the spoils can be spread evenly along the transmission R/W along spans between Structures 1-4.

6) Q: Will there be any stumps that need to be pulled prior to driving caissons for structures?

A: No. To clarify, Structures 1-4 will be installed far enough away from the tree line so that there won't be any trees or stumps interfering with the installation of caissons. Tree clearing will not be required prior to the transmission project.

7) Q: Can Structure 5 be relocated so that it will be between existing pole and Wellcome Substation to reuse existing transmission lines.

A: Structure 5 location is between the existing transmission pole and Wellcome Substation. This will allow the existing transmission line crossing US-264 to be reused on new deadend framing.

BOVIET Transmission Pre-Bid Q&A

Date: 3/11/2026

8) Q: Will matting be required for the installation of Structure 6?

A: The contractor will be responsible for landscaping in the area around Structure 6. We recommend that the contractor use matting to minimize impacts to landscaping in front of Avient. Landscaping will not be required for Structures 1-4 as well as Structure 5. The contractor will only be responsible for removing spoils and cleaning trash in those locations.

9) Q: When will Boviet Substation construction begin?

A: GUC plans to begin construction sometime in July (approximately). Please refer to GUC website for exact start date once the bid is released.