

QUESTIONS AND ANSWERS FOR:

RFQ # 20-60, 01/05/2021 FOR

Engineering Services for Gas Distribution System and LNG SCADA System Upgrade

1. Is there a technical lead we could have a brief call with to discuss the specified software/hardware architecture? **To ensure that consistent information is provided to all vendors, we prefer that any questions be submitted in writing so that the responses can be shared with all interested parties.**
2. Is the technical direction already determined, or will there be an opportunity to offer a solution outside of what is specified in the RFQ? **The current direction includes migration to a virtual server format utilizing Hyper V VM software with the current Windows server software. This includes the AutoSol OPC implementation to mitigate any future upgrades. The reason being to keep connectivity between older GFC units and new FB platform.**