

QUESTIONS AND ANSWERS FOR:

RFB # 21-01, 02/09/2021 FOR

Replacement of 115 KV Transmission Structures

Along Circuit 15,16 and 17

1. Will there be an outage to perform the pole replacements or will the work need to be completed while the line is energized?

All 115 kV transmission circuits will be de-energized for pole replacements. Distribution circuits will be de-energized where possible, however, GUC does not guarantee that all distribution circuits will be de-energized for pole replacements. Contractors should plan accordingly.

2. Will you be sending an Excel version of the pricing sheet?

We do not provide Excel versions of the pricing sheet.