

**QUESTIONS AND ANSWERS FOR:**

**RFB # 21-02, 02/02/2021 FOR TRANSFORMERS**

1. Please have the customer verify the voltages on the single phase pads. We need to make sure they are wanting 12470grdy/7200 primary and 240/120 (3lv bushings) low voltage. *Correct, 12470grdy/7200 primary and 240/120 (3lv bushings) low voltage*