

**QUESTIONS AND ANSWERS FOR:**

**RFB # 20-49, 10/21/2020 FOR**

**TWO (2) 20 MVA, 115 TO 13.2Y/7.62 kV POWER TRANSFORMER**

**WITH LOAD TAP CHANGER FOR SUGG PARKWAY & SPARE**

- 1) Is the existing pad an active or a temporary pad? **Permanent installation**
- 2) Can we deliver two units together? Per 7.0, The manufacturer shall provide (and include in his base quotation) the services of a Field Service Engineer for a period of three (3) working days. Is this 3 days for each unit, or for both units? **One unit will be dressed out upon acceptance. Three days for one unit is required.**