Greenville Utilities Commission Greenville, North Carolina Q&A's for RFP for Walkways Due October 8, 2020 at 3:00 PM (EDST)

Questions:

- 1. Can the walkway be 36" rather than 24" as indicated as a 'minimum' in RFP?
- 2. Are any pictures available of existing clarifier tanks?
- 3. What is the structure that these new platform extensions will attach too? Any drawings available?
- 4. Can ITAC perform an onsite scoping visit prior to submitting the sealed proposal by due date of October 8th by 3:00 PM (EDST)? If so, what is a good time/day to get the scoping visit scheduled?
- 5. What are the onsite construction hours where these platforms and construction activities can commence?
- 6. Any special PPE required when performing construction duties in this area?
- 7. Does this project require formal review/drawing packages to be furnished, sealed by a Licensed PE in the state of North Carolina?
- 8. Are we quoting platform lengths that are on the drawing, or are those measurements approximate lengths?
- 9. Will there be a site visit of the space so we can get a better idea of what the existing conditions are?

Answers:

- 1. They can be 36" but we prefer 24".
- 2. Drawing, see the RFP at: <u>www.guc.com</u>. #20-46
- 3. The structure is hard concrete with rebar.
- 4. Thursday, <u>September 24 at 10:00 am</u>. Contact: Cliff McGuffin at 252-551-3385 office or 252-414-6588 cell. Notify Cliff in advance so he knows you plan to attend site visit.
- 5. We are 24/7 facility so they could work anytime they want.
- 6. We require fall protection at all times while working on or in the basin.
- 7. We are not requiring stamped drawings since these will be platforms that are not accessed daily.
- 8. The lengths are approximate but should be within a few feet or less.
- 9. Thursday, <u>September 24 at 10:00 am.</u> Contact: Cliff McGuffin at 252-551-3385 office or 252-414-6588 cell. Notify Cliff in advance so he knows you plan to attend site visit.